



MAX 4 UNITS

NOTE:

JP1

Short the RS485 Terminator (J1) on the last MX4 unit wired along the RS485 bus.

JP2

Assign different unit number (J2) for each MX4 unit when multiple controllers are connected.

Title MX4 RS485 NETWORK WIRING		
Size A3	Number MX04-102	Revision 1
Date: 16-Jul-2009	Sheet of 1 OF 1	Drawn By: STACY WONG
File: D:\MX4\WIRING-1\MZI04-2.SCH		